

GOVERNMENT OF WEST BENGAL
SAKTIGARH SUB DISTRICT WATER TESTING LABORATORY
WATER AND SANITATION SECTION
PUBLIC HEALTH ENGINEERING DIRECTORATE
SAKTIGARH, BURDWAN - II, PURBA BARDHAMAN.
WATER SAMPLE TEST REPORT OF DELHI PUBLIC SCHOOL:-AUGUST -2026
DISE NO-19250700302, GRN NO-192026270172809325



SL N O	BLOCK	GP	VILLAGE	HABITATION	LOCATION	DATE	CHEMICAL						BACTERIOLOGICAL	
							pH	TUR	TDS	Fe	Mn	Total Hardness	T.C.	F.C
1	GALSI-2	SATINANDI	BELGRAM	BELGRAM	BACKSIDE OF OFFICE ROOM	20.08.2026	7.01	0.26	146.6	0.12	0.02	131.9	0	0

Desirable Limit:- pH - 6.5 to 8.5, Turbidity - <5, Hardness:- 300 to 600 mg/lit,
Iron:-1 mg/lit, Mn - 0.3 mg/lit, Bacteriological Safe:-T.C-0, F.C. Must be - 0.

Rajkrishna
CHEMIST

[Signature]
BACTERIOLOGIST

C/S.
[Signature]
Assistant Engineer
RWS Burdwan Sub-Divn.
P.H. Engg. Dte.
Nababhat, Purba Bardhaman



**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. _____

Date: 10.09.2026

It is certified that an inspection team headed by SWAPAN KUMAR GHOSH,
Joint Block Development Officer (Name of Officers with
 designation) from Galsi-II B.D.O. office. (Name of
 Department/Office) inspected the Delhi Public School,
Belgram, Purba Bardhaman. (Name & address of
 the School) on 10/09/2026 and found that the Delhi Public
School (Name of school) has safe

drinking water facilities for the students and members of staff of the institution and is maintaining the
 hygienic sanitation condition in the school building & the campus as per the norms prescribed by the
 Central/State/U.T. Govt.

The above valid for a period of 10/09/2027
(for one year)

Signature with seal:



10/09/26
 Joint Block Development Officer
 Galsi-II, Purba Bardhaman

Name: SWAPAN KUMAR GHOSH

Designation: Joint Block Develop-
ment, Galsi-II Dev. Block.
GALSI : PURBA BARDHAMAN.

To

The Principal,
Delhi public School,
Belgram, Purba Bardhaman.

(Name & Address of the Institution)

