



Government Of West Bengal
Office Of The Divisional Fire Officer,Purba Bardhaman
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Burdwan, P.O.- Rajbati, Pin :- 713104

Memo no.:IND/WB/FES/20192020/74940

Date: 30-07-2023

From:

Divisional Fire Officer,Purba Bardhaman
West Bengal Fire & Emergency Services

To: Delhi Public School

Vill. and Mouza- Belgram, Plot no. 2143, 2145, 2147, 2151, Kh. no. 1612, 1614, 1615, J.L no. 117, P.S. Galsi, Dist. Purba Bardhaman, Pin - 713141.

Sub: Renewal of Fire Safety certificate for the occupancy of an Existing Construction of G+3 Storied under group of Educational Building name and style " DELHI PUBLIC SCHOOL " , at the premises no. - Vill. and Mouza- Belgram, Plot no. 2143, 2145, 2147, 2151, Kh. no. 1612, 1614, 1615, J.L no. 117, P.S. Galsi, Dist. Purba Bardhaman, Pin - 713141.

This is in reference to your application no. 0125191230300156 dated 24-07-2023 regarding the Renewal of Fire Safety certificate for the occupancy of an Existing Construction of G+3 Storied under group of Educational Building name and style " DELHI PUBLIC SCHOOL " , at the premises no. - Vill. and Mouza- Belgram, Plot no. 2143, 2145, 2147, 2151, Kh. no. 1612, 1614, 1615, J.L no. 117, P.S. Galsi, Dist. Purba Bardhaman, Pin - 713141.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1.1.Driveway must be free of any type of obstruction for easy movement of fire appliances, No parking will be allowed on the drive way. Basement shall not be used other than Car parking.
2. The interior finish decoration of the building shall be made low flame spread materials: conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
- 4.Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.

- 5.The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
- 6.Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
- 7.Transformer and switch gear room shall be protected with automatic co2 or DCP fire.extinguisher conforming I.S specification.
- 8.First aid firefighting system shall be provided as per I.S specification.
9. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
- 10.Fire License shall have to be obtained for storing and processing with highly combustible articles.
- 11.The Renewal of Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

N.B. :

1. Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Certificate will be treated as cancelled .

Validity unknown

Digitally signed by SHYAM
CHANDRA MENDAL
Date: 2023.07.30 18:47:47 IST

Divisional Fire Officer,Purba Bardhaman
West Bengal Fire & Emergency Services

Rajesh Bhagat
MANAGER
DELHI PUBLIC SCHOOL
BURDWAN

Sheli Ghosh Banerjee
Principal
DELHI PUBLIC SCHOOL
BURDWAN